



2011

ANNUAL DRINKING WATER QUALITY REPORT

PWSID #:

6430037

NAME: Municipal Authority of the Borough of Greenville
Greenville Water Authority website: www.gmwa.info

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it, or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact The Greenville Water Authority at [724-588-4340](tel:724-588-4340).

We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the second Wednesday of every month at 44 Clinton Street, Greenville PA 16125 at 5:30 PM

SOURCE OF WATER:

Our water source is: SHENANGO RIVER

The water flows naturally from our water source, the Shenango River, to a raw water chamber in the plant through four intake screens.

A Source Water Assessment of our source was completed in 2003 by the PA Department of Environmental Protection (PADEP). The Assessment has found that our source is potentially most susceptible to road de-icing materials, accidental spills along roads and leaks in underground storage tanks. Overall, our source has little risk of significant contamination. Summary reports of the Assessment are available by writing to Greenville Water Authority, 44 Clinton Street, Greenville, PA 16125 and will be available on the PADEP website at www.depweb.state.pa.us (Keyword: "source water"). Complete reports were distributed to municipalities, water suppliers, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PADEP Meadville Regional Office, Records Management Unit at (814) 332-6899.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline.
(800-426-4791)**

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2011. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	4	MRDLG 4	3.97	1.2 - 3.97	ppm	2/5/11	N	Water additive to control microbes.
Haloacetic Acids	60	N/A	39	2 – 39 18 (a)	ppb	Quarterly	N	By-product of Disinfection
Total Trihalomethanes	80	N/A	63	30 – 63 44 (a)	ppb	Quarterly	N	By-product of Chlorination
Nitrates	10	10	0.11	0.11	ppm	5/12/11	N	Runoff from fertilizer, leaching from septic tanks, sewage, Erosion of natural deposits.

Barium	2	2	0.02	0.02	ppm	11/02/11	N	Discharge of drilling waste, metal refineries; Erosion of natural deposits
--------	---	---	------	------	-----	----------	---	--

(a) Yearly Running Average

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Units	Sample Date	Violation Y/N	Sources of Contamination
Di(2-ethylhexyl) Phthalate (SOC)	6	0	0.6	ppb	5/12/11	N	Discharge from rubber and chemical factories
Combined Radium	5	0	2.01	pCi/L	11/02/11	N	Erosion of natural deposits.

Total Organic Carbon Contaminant	Range of % Removal Required	Range of % Removal Achieved	Number of Quarters Out of Compliance	Violation Y/N	Sources of Contamination
TOC	25.0 - 45.0	20.6 – 65.1	0	N	Naturally present in the environment

Lead and Copper Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation of TT-Y/N	Sources of Contamination
Lead	15	0	7 8/10/2010	ppb	0	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.267 8/10/2010	ppm	0	N	Corrosion of household Plumbing.

Microbial Contaminants	MCL	MCLG	Highest # or % of Positive Samples	Violation Y/N	Typical Sources of Contamination
Total Coliform Bacteria	10 Samples Per Month	0	0	N	Naturally present in the environment.
Fecal Coliform Bacteria or <i>E. coli</i>	10 Samples Per Month	0	0	N	Human and animal fecal waste.

Turbidity Contaminant	MCL	MCLG	Level Detected	Sample Date	Violation of TT Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement	N/A	0.23 NTU	9/10/11	N	soil runoff

	TT= at least 95% of monthly samples \leq 0.3 NTU		98.33%	04/11	N	
--	--	--	--------	-------	---	--

OTHER VIOLATIONS:

The Authority sampled for Mercury (IOC), Combined Uranium and Combined Radium however, failed to report results correctly.

OTHER INFORMATION:

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Greenville Water Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a

health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

EMERGENCY NOTIFICATION:

Due to changing regulations from the US Environmental Protection Agency and the Pennsylvania Department of Environmental Protection Agency you are encouraged to go to the Authority's website at www.gmwa.info and enter your contact information by clicking on the SWIFT911 box towards the bottom of the home page for required notifications.